



1 Ground Floor Fire Strategy plan
1 : 50

LEGEND

S1

Fire Exit

↑

Illuminated singage

S2

Fire Exit

↓

Illuminated singage

S3

Fire Exit

↔

Illuminated singage

30 Mins Fire Protection Integrity & Insulation

60 Mins Fire Protection Integrity & Insulation

FD30 - SS
xx/xx/KL

Fire Door Keep Locked Shut

FD30 - SS
xx/xx/KS

Fire Door Keep Shut

FD30 - SS
SC/xx/xx

Self Closing

FD30 - SS
xx/VP/xx

Doors Fitted With Vision Panels

FD30 - SS
xx/xx/xx

Fire Door 30 Mins Smoke Sealed Fire Resistant (Integrity & Insulation)

Length m
Time sec

←

Travel Distance (worst Case Distances Illustrated)

↑

Primary Fire Escape Door

↑

Secondary Fire Escape Door

30min Store Compartment

S

Smoke Detector with sounder BS5839-1

S

Smoke Detector BS5839-1

⊗

Alarm sounder with beacon light

Fire Control Panel BS5839-1

Fire Alarm Call Point BS5839-1

⊗

Emergency Light with battery back-up BS 5266-1 to be connected to fire alarm

H

Heat Detector

NOTE:

Fire Alarm System to BS5839-1

Emergency Lighting to BS3864-1 & BS5499-4

Drawing to read in conjunction with M&E information

Information to be reviewed by fire consultant.

