



## Copthorne Recreation Ground Project

### Tender for Contract E: Civils Package 2

### Questions & Answers

Question	Response
Is it possible to extend the deadline?	We will not be extending the closing date at this time.
Is it possible to tender for the Playground contract and/or the MUGA contract?	No - the MUGA & Playground have already been through separate tender exercises and those tendering have been advised of the outcome.
Is it possible to purchase the playground equipment from the identified playground supplier and install it for them?	No
Will a petrol interceptor be required for the car park?	As we see it, a petrol interceptor is unnecessary because the soakaway is designated for the play area, and rainwater from the car park is filtered through the tarmac and Type 3 before reaching the soakaway, which by then would ordinarily be subsoil. That said, the drainage design is still subject to approval by Mid Sussex District Council, so they may raise this point.
Will the permeable tarmac be durable in the turning area of the car park?	The specified tarmac is designed for use in car parks.
Is any more guidance being given about how scoring will be done?	No further guidance is being given, other than what is already in the invitation to tender pack.