



LEGEND

- Fire Exit Illuminated singage
- Fire Exit Illuminated singage
- Fire Exit Illuminated singage
- 30 Mins Fire Protection Integrity & Insulation
- 60 Mins Fire Protection Integrity & Insulation
- FD30 - SS xx/xx/xx
- FD30 - SS xx/xx/xx
- FD30 - SS SC/xx/xx
- FD30 - SS xx/xx/xx
- FD30 - SS SC/VP/xx
- FD30 - SS xx/xx/xx
- Length m Time sec
- Travel Distance (worst Case Distances Illustrated)
- Primary Fire Escape Door
- Secondary Fire Escape Door
- 30min Store Compartment
- Smoke Detector with sounder BS5839-1
- Smoke Detector BS5839-1
- Alarm sounder with beacon light
- Fire Control Panel BS5839-1
- Fire Alarm Call Point BS5839-1
- Emergency Light with battery back-up BS 5266-1 to be connected to fire alarm
- Heat Detector
- Fire Alarm System to BS5839-1
- Emergency Lighting to BS3864-1 & BS5499-4
- Roller Shutter linked to fire alarm.
- Drawing to read in conjunction with M&E Information
- Information to be reviewed by fire consultant.

Ground Floor - Fire Strategy
1 : 50

TENDER ISSUE

All dimensions are to be checked on site and any discrepancies reported to the architect before work commences. Figured dimensions only are to be taken from this drawing. This drawing is to be read in conjunction with all relevant consultants and/or specialists drawings/documents and any discrepancies or variations notified to the architect before work commences. This drawing is copyright and may not be reproduced in any form, without the consent of the architect.

CLIENT
Wickham & Knowle Parish Council

TITLE
Extension at Knowle Village Hall
Knowle Avenue, Fareham PO15 5GR
Proposed Ground Floor Fire Strategy Plan

Scale @ A1As indicated
Date : Feb 25

Drawn by : MC
Checked by MH

Drawing No:
24-004-317

Revisio
n:

Spaces, 4500 Parkway
Solent Business Park
Whitley, Fareham
Hampshire PO15 7AZ
T: 01329832405
e: office@axismail.co.uk
w: axisarchitecture.co.uk

