


LEGEND

- S1 Fire Exit illuminated singage
- S2 Fire Exit illuminated singage
- S3 Fire Exit illuminated singage
- 30 Mins Fire Protection Integrity & Insulation
- 60 Mins Fire Protection Integrity & Insulation
- FD 30 - SS xx/xx/KL Fire Door Keep Locked Shut
- FD 30 - SS xx/xx/KS Fire Door Keep Shut
- FD 30 - SS SC/xx/xx Self Closing
- FD 30 - SS xx/VP/xx Doors Fitted With Vision Panels
- FD 30 - SS xx/xx/xx Fire Door 30 Mins Smoke Sealed Fire Resistant (Integrity & Insulation)
- Length m Time sec
- Travel Distance (worst Case Distances Illustrated)
- Primary Fire Escape Door
- Secondary Fire Escape Door
- 30min Store Compartment
- Smoke Detector with sounder BS5839-1
- Smoke Detector BS5839-1
- Alarm sounder with beacon light
- Fire Control Panel BS5839-1
- Fire Alam Call Point BS5839-1
- Emergency Light with battery back-up BS 5266-1 to be connected to fire alarm

NOTE: Heat Detector  
Fire Alarm System to BS5839-1  
Emergency Lighting to BS3864-1 & BS5499-4  
Roller Shutter linked to fire alarm.  
Drawing to read in conjunction with M&E information  
Information to be reviewed by fire consulatant.

First Floor - Fire Strategy  
1 : 50

TENDER ISSUE



CLIENT  
Wickham & Knowle Parish Council

TITLE  
Extension at Knowle Village Hall  
Knowle Avenue, Fareham PO17 5GR  
Proposed First Floor Fire Strategy Plan

Spaces, 4500 Parkway  
Solent Business Park  
Whitley, Fareham  
Hampshire PO15 7AZ  
T: 01323832405  
e: office@axismail.co.uk  
w: axisarchitecture.co.uk



Scale @ A1: As indicated  
Date: Feb 25  
Drawn by: MC  
Checked by: MH

Drawing No: 24-004-318

Revision:

Revision Date Initial