

ALL GREYED ITEMS ARE OUTSIDE
THE SCOPE OF THIS DRAWING

UNCONFIRMED. POTENTIAL TO
FACILITATE UNDERGROUND ROUTE
TO LINK REVELLER MAIN BUILDING
WITH THE EXTENSION SUBJECT TO
THE FINDINGS OF THE STRIP OUT
WORKS.

THIS DRAWING IS INDICATIVE AND REPRESENTS ONLY THE
DESIGN INTENT, THE CONTRACTOR MUST PRODUCE FULLY
CO-ORDINATED WORKING / INSTALLATION DRAWINGS AS
REFERRED TO IN THE CONTRACT DOCUMENTATION

NOTES

- DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS INDICATED
ARE IN MILLIMETRES.
- THIS IS NOT A CONSTRUCTION DRAWING.
- DRAWING TO BE READ IN CONJUNCTION WITH SPECIFICATION,
DOCUMENTATION, DRAWINGS & ALL RELEVANT BRITISH STANDARD
DOCUMENTS
- THE WORKS COMPRISE MANUFACTURING, FACTORY TESTING,
SUPPLY, DELIVERING TO SITE, MANEUVERING INTO POSITION,
ERECTION, CONNECTING UP, TESTING, COMMISSIONING,
PERFORMANCE TESTING AND HANDING OVER IN WORKING ORDER
THE COMPLETE ELECTRICAL INSTALLATION.
- CONTAINMENT SYSTEMS AND ASSOCIATED FITTINGS SHALL BE
MANUFACTURED IN ACCORDANCE WITH THE REQUIREMENTS OF BS
EN 61537.
- MANUFACTURER'S BENDS, TEES, REDUCERS ETC. SHALL BE USED
THROUGHOUT AND SIZED TO SUIT THE BENDING RADIUS.
- CONTAINMENT SHALL BE SIZED TO INCLUDE THE SPARE CAPACITY
PERCENT AS REQUESTED IN THE SPECIFICATION.
- CONTAINMENT SHALL BE COORDINATED WITH THE BUILDING
STRUCTURE AND OTHER SERVICES WITHIN THE BUILDING.
- WHERE SERVICES PASS THROUGH A FIRE RATED COMPARTMENT
THE OPENINGS SHALL BE CORRECTLY SEALED AS TO MAINTAIN
THE FIRE INTEGRITY OF THE ENCLOSURE.
- THE CONTRACTOR MUST TAKE THE UTMOST CARE WHEN
INSTALLING THE CONTAINMENT AND DRILLING NEW HOLES FOR
SUPPORTS, THE APPROPRIATE COMMUNICATION MUST BE TAKEN
BETWEEN HRP, HAH AND THE ARCHITECT.
- ALL FINAL SETTING OUT BY JFA ARCHITECTS.

LEGEND

- LV UNDERFLOOR CABLE TRAY
- ELV UNDERFLOOR CABLE BASKET
- FIRE ALARM UNDERFLOOR CABLE TRAY
- UNDERFLOOR LIGHTING CABLE TRAY
- LV SUBMAINS UNDERFLOOR CABLE TRAY
- DISTRIBUTION BOARD
- PANEL BOARD
- TPN TPN INCOMING SUPPLY

P06	DRAFT TENDER ISSUE	JR	JR	AJ	29.10.25
P05	STAGE 4B UPDATE	TG	JR	AJ	18.07.25
P04	STAGE 4B ISSUE	TG	JR	AJ	13.06.25
P03	STAGE 4A ISSUE	JG	JR	AJ	04.04.25
P02	STAGE 3 ISSUE	TG	JR	AJ	25.11.24
P01	STAGE 3 COORDINATION ISSUE	JG	JR	AJ	08.11.24
REV	DESCRIPTION	BY	CHK	APP	DATE

Project Status:
DRAFT TENDER ISSUE



ENGINEERING POWERED BY THE PAST
BUILDING THE FUTURE

Unit A2, Hatchers Yard
9 Tanner Street
London, SE1 3LE
T 44 (0) 203 755 5960
www.harleyhaddow.com

Project: 313293
**TOWER OF LONDON
REVELLER**

Drawing Title:
**GROUND FLOOR
LOW LEVEL
CONTAINMENT LAYOUT**

Scale @ A1 1:100	Date NOV 2024	Engineer JR	Revision P06
---------------------	------------------	----------------	-----------------