

















FILENAME: Z:\PROJECTS\313293 - TOL - REVELLER PROJECT\07\HAH DRAWINGS\02 CAD\02 ELECTRICAL\313293-HAH-01-UB-D-E-06200.DWG | PLOTTED DATE: 29 October 2025 09:32:09

ALL GREYED ITEMS ARE OUTSIDE THE SCOPE OF THIS DRAWING

LEGEND

-  DISTRIBUTION BOARD
-  PANEL BOARD
-  TPN ISOLATOR
-  SPN ISOLATOR
-  DOUBLE SWITCH SOCKET OUTLET
-  CONNECTION POINT: LOW LEVEL- CABLE OUTLET PLATE
HIGH LEVEL- MAINTENANCE FREE JUNCTION BOX
-  FUSED CONNECTION UNIT
-  SWITCHED FUSED CONNECTION UNIT
-  UNSWITCHED SOCKET OUTLET
-  GRID SWITCH
-  16A COMMANDO SOCKET
-  DISABLED ALARM CONTROL PANEL
-  RESET BUTTON
-  OVERHEAD DOOR LIGHT
-  DISABLED PULL CORD
-  AV ITEM- REFER TO AV LAYOUTS
FOR FURTHER INFORMATION

ABBREVIATIONS

- AD AUTOMATIC DOOR
- AHU AIR HANDLING UNIT
- DAC DISABLED ALARM CONTROLLER PANEL
- DEP DOOR ENTRY PANEL
- DHP DOOR HOLD PANEL
- DW DISHWASHER
- EF EXTRACT FAN
- EH ELECTRIC HEATER
- FCU FAN COIL UNIT
- FR FRIDGE
- HD HAND DRYER
- IL INDUCTION LOOP
- MC METALCLAD
- MVHR MECHANICAL VENTILATION WITH HEAT RECOVERY
- MW MICROWAVE
- PH PANEL HEATER
- SS SECURITY SCANNER
- VRF VARIABLE REFRIGERANT FLOW



THIS DRAWING IS INDICATIVE AND REPRESENTS ONLY THE DESIGN INTENT, THE CONTRACTOR MUST PRODUCE FULLY CO-ORDINATED WORKING / INSTALLATION DRAWINGS AS REFERRED TO IN THE CONTRACT DOCUMENTATION

NOTES

1. DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS INDICATED ARE IN MILLIMETRES.
2. THIS IS NOT A CONSTRUCTION DRAWING.
3. ALL ELECTRICAL WORKS SHALL COMPLY WITH 18TH EDITION IET WIRING REGS BS7671:2018/A2 (2022) INCLUDING ALL CURRENT AMENDMENTS AND GUIDANCE NOTES AND THE CURRENT BUILDING STANDARDS REGULATIONS.
4. THE INSTALLATION SHALL ONLY BE CERTIFIED BY A PERSON OR A COMPANY HAVING MEMBERSHIP TO S.E.I.E.C.T. OR N.I.C.E.I.C. OR SIMILAR ELECTRICAL SCHEMES.
5. THIS DRAWING IS NOT TO BE SCALED, FIGURED DIMENSIONS ONLY TO BE TAKEN.
6. ELECTRICAL ACCESSORY POSITIONS ARE INDICATIVE ONLY. ELECTRICAL CONTRACTOR TO REFER TO JFA ARCHITECTS SETTING OUT DRAWINGS FOR EXACT DIMENSIONS / LOCATIONS.
7. CONTRACTOR TO ALLOW FOR COORDINATION OF ALL MECHANICAL AND ELECTRICAL SERVICES THROUGHOUT.
8. CONTRACTOR TO ALLOW FOR SITE COORDINATION WITH OTHER TRADE/SERVICE INSTALLATIONS.
9. ALL FINAL CIRCUIT WIRING TO BE MULTICORE FLEXISHEILD TYPE.
10. SOCKET / DATA OUTLETS TO BE FLUSH MOUNTED THROUGHOUT.
11. SOCKET OUTLET FINISHES TBC BY JFA ARCHITECTS.
12. SOCKET OUTLETS TO ALL PLANT / STORE SPACES TO BE SURFACE MOUNTED METAL CLAD.
13. ALL ELECTRICAL OUTLETS TO BE FULLY AGREED / SIGNED OFF BY JFA ARCHITECTS PRIOR TO INSTALLATION.
14. ALL CABLE / TV / DATA OUTLETS THROUGHOUT TO MATCH OUTLET FINISH WITHIN GIVEN SPACE.
15. ALL FINAL WAP LOCATIONS TO BE CONFIRMED WITH AV SPECIALIST. ACCESS POINTS & ASSOCIATED POWER SERVICES TO BE CEILING MOUNTED.
16. ACCESSORY PLATES WITHIN THE KITCHEN SHALL BE ENGRAVED WITH THE NAME OF EQUIPMENT SERVED (5mm BLACK LETTERING).
17. THE ELECTRICAL CONTRACTOR SHALL ENSURE THAT SOCKET OUTLETS ETC. ARE NOT INSTALLED BACK TO BACK TO ENSURE THE ACOUSTIC INTEGRITY OF THE WALLS BETWEEN THEM IS MAINTAINED.
18. EVERY SERVICE, FITTING AND PIECE OF EQUIPMENT IS PROVIDED SO AS TO SERVE A PURPOSE OF THE BUILDING REGULATIONS AND IS TO BE DESIGNED, INSTALLED AND COMMISSIONED IN SUCH A WAY TO FULFIL THOSE PURPOSES.
12. ELECTRICAL CONTRACTOR TO ALLOW FOR INSTALLING, TESTING & COMMISSIONING OF ALL ACCESSORIES. THEN REMOVAL TO ALLOW FOR FINAL DECORATION.
13. POWER SUPPLIES FOR ALL MECHANICAL PLANT ARE SUBJECT TO CHANGE. REFER TO MECHANICAL LAYOUTS FOR DETAILS.
14. THIS DRAWING DOES NOT REMOVE THE CONTRACTORS RESPONSIBILITY TO:
 - PRODUCE THEIR OWN WORKING DRAWINGS.
 - TAKE ALL SITE DIMENSIONS AS REQUIRED.
 - COORDINATE WITH OTHER SERVICES AND THE BUILDING STRUCTURE

P06 DRAFT TENDER ISSUE	JR	JR	A3	29.10.25
P05 STAGE 4B UPDATE	TG	JR	A3	18.07.25
P04 STAGE 4B ISSUE	TG	JR	A3	13.06.25
P03 STAGE 4A ISSUE	JG	JR	A3	04.04.25
P02 STAGE 3 ISSUE	TG	JR	A3	25.11.24
P01 STAGE 3 COORDINATION ISSUE	JG	JR	A3	08.11.24

REV	DESCRIPTION	BY	CHK	APP	DATE
-----	-------------	----	-----	-----	------

Project Status:
DRAFT TENDER ISSUE



ENGINEERING POWERED BY THE PAST
BUILDING THE FUTURE

Unit A2, Hatchers Yard
9 Tanner Street
London, SE1 3LE
T 44 (0) 203 755 9360
www.harleyhaddow.com

Project: 313293
TOWER OF LONDON
REVELLER

Drawing Title:
MOAT LEVEL
SMALL POWER
LAYOUT

Scale @ A1 1:100	Date NOV 2024	Engineer JR	Revision P06
---------------------	------------------	----------------	-----------------