



CERTIFICATE OF DISINFECTION

CERTIFICATE NO: 27079

CLIENT: TUTBURY PARISH COUNCIL

SITE: TUTBURY PAVILION

SITE USAGE: HOT AND COLD WATER SERVICES

DATE OF COMPLETION: 22.11.2025

DATE OF CERTIFICATE: 30.11.2025

GUIDANCE APPLYING TO THE WORK: HSG274 PART 2

WORK CARRIED OUT

COLD WATER TANKS: CLEANED AND DISINFECTED

TANK COLD WATER SYSTEM: DISINFECTED

MAINS COLD WATER SYSTEM: N/A

HOT WATER SYSTEM: DISINFECTED

MIXING VALVES, SHOWERS, TAPS ETC: DISINFECTED

MICROBIOLOGICAL TESTS: SAMPLE TAKEN RESULTS TO FOLLOW

DISINFECTION METHOD:

The system was filled with OxyL-pro Hydrogen Peroxide at a concentration of 50ppm for a contact period of one hour.

The system was then flushed with clean water until the OxyL-pro Hydrogen Peroxide levels were <0.1ppm.

SIGNED.....